


COMPONENTES DEL SISTEMA



KIT006	FILTRO DE SEDIMENTO EWS-FP121A		
No.	Componente	Descripción	Cantidad
1	CFL052	HOUSING CONTROL DE FLUJO 11/2" MAX 40 GPM (4 AGUJEROS)	1.00
2	CFL053	INSERTO PARA CONTROL DE FLUJO 5.0 GPM	1.00
3	CFL054	INSERTO PARA CONTROL DE FLUJO 10GPM	3.00
4	HBL013	HUB AND LATERAL P/TANQUE 18" A 21 JD302 (HU6370)	1.00
5	MFI002	TURBIDEX * 22.7 Kgs.	7.00
6	MFL605	GRAVA FILTRANTE #1	0.50
7	MFL607	GRAVA FILTRANTE #2	0.70
8	TNQ106	TANQUE PARA FILTRO FRP 21X62	1.00
9	VVL027	VALVULA AUTO P/FILTRO 2" 44GPM F75B1	1.00

ESPECIFICACIONES		
FLUJO EN SERVICIO @ 10 GPM FT²		24
FLUJO EN RETROLAVADO @ 15 GPM FT²		35
TEMPERATURA MAXIMA		50 °C
PRESIÓN MAXIMA		100 PSI
PRESIÓN MINIMA DE ENTRADA		25 PSI
CONEXIÓN ELECTRICA		
	VOLTAJE	110 V
	FRECUENCIA	60 Hz
CONEXIONES HIDRAULICAS		
	ENTRADA	2
	SALIDA	2
	DRENAJE	2

PROPIEDAD INTELECTUAL DE EWS COMERRSA. PROHIBO LA REPRODUCCION PARCIAL O TOTAL DE ESTE DOCUMENTO

EWS
FP121A

FILTRO DE SEDIMENTO AUTOMATICO

